



Input 1: Enable Channel  
 Hold and reset Timer  
 Input 2: Hold and reset Timer  
 PNP Out: Pulse if timer < 3 min  
 On if timer < 1 min  
 Latching Relay Out:  
 Closed if channel enabled

DO NOT SCALE DRAWING	REVISION	V 1.0
Woodrell Machine and Control		
TITLE:		
Wiring Diagram		
DWG NO.	SLRC-4	A4
SCALE:1:1	SHEET 1 OF 1	